

Kodiak: Regulator Building**FY2010 Request: \$2,800,000****Reference No: 47750****AP/AL:** Allocation**Category:** Transportation**Location:** Kodiak**House District:** Kodiak (HD 36)**Estimated Project Dates:** 07/01/2009 - 06/30/2014**Appropriation:** Airport Improvement Program**Project Type:** Construction**Contact:** Christine Klein**Contact Phone:** (907)269-0724**Brief Summary and Statement of Need:**

Replace the regulator building at the Kodiak Airport. This project contributes to the Department's Mission by reducing injuries, fatalities and property damage and by improving the mobility of people and goods.

Funding:	FY2010	FY2011	FY2012	FY2013	FY2014	FY2015	Total
Fed Rcpts	\$2,800,000						\$2,800,000
Total:	\$2,800,000	\$0	\$0	\$0	\$0	\$0	\$2,800,000

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	
Totals:	0	0

Additional Information / Prior Funding History:

None.

Project Description/Justification:

The existing regulator building at Kodiak Airport is a World War II era bunker that is unsafe to operate in. Its roof has leaked in recent years and the building is not code compliant. The primary electrical voltage that serves this building is 2,400 volt 3 phase power. Due to regulator design deficiencies, there is no building "main disconnect switch." A fault could produce an extreme arc flash explosion. No one but the regional electrician is allowed into the building due to safety concerns.

This request reflects a revised engineer's estimate.