

Iditarod Area - Blackwell School Heating Renovation & Site Repair **FY2001 Request: \$280,010**
Reference No: AMD 33537

AP/AL: Appropriation **Project Type:** Renewal and Replacement
Category: Education
Location: Anvik **Contact:** Karen J. Rehfeld
House District: Rural Interior (HD 36) **Contact Phone:** (907)465-8650
Estimated Project Dates: 07/01/2000 - 06/30/2005

Brief Summary and Statement of Need:

This project is the FY2001 Major Maintenance Grant Fund Priority #21 and is scheduled to begin in FY2001.

Funding:	<u>FY2001</u>	<u>FY2002</u>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>Total</u>
AHFC Bonds	\$280,010						\$280,010
Total:	\$280,010	\$0	\$0	\$0	\$0	\$0	\$280,010

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	
Totals:	0	0

Additional Information / Prior Funding History:

Project Description/Justification:

The 8,240 square foot K-12 and the existing heating system are 20 years old. System failures have resulted in interior oil spills and exhaust fumes forcing the school to close until the necessary repairs could be made. The Division of Energy has completed design plans for a new boiler system and waste heat connection to the Alaska Village Electric Corporation. The installation will require a modular building and twin boilers with a heat exchanger retrofit. Proposed cost: \$285,725.