

Lower Yukon - Emmonak Mechanical System Upgrade**FY2001 Request: \$715,772****Reference No: AMD 33568****AP/AL:** Appropriation**Project Type:** Renewal and Replacement**Category:** Education**Location:** Emmonak**Contact:** Karen J. Rehfeld**House District:** Nome, Lower Yukon (HD 38)**Contact Phone:** (907)465-8650**Estimated Project Dates:** 07/01/2000 - 06/30/2005**Brief Summary and Statement of Need:**

This project is the FY2001 Major Maintenance Grant Fund Priority #42 and is scheduled to begin in FY2002.

Funding:	<u>FY2001</u>	<u>FY2002</u>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>Total</u>
AHFC Bonds	\$715,772						\$715,772
Total:	\$715,772	\$0	\$0	\$0	\$0	\$0	\$715,772

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	
Totals:	0	0

Additional Information / Prior Funding History:**Project Description/Justification:**

This project will address numerous fire code deficiencies found to exist in the original 42-year-old, 39,790 square foot construction. These include sweat copper fuel piping, lack of fire dampers on ductwork, furnaces with serious backdrafting, floor failure in the boiler room, and various non-UL rated components. Proposed cost: \$730,380.