

Dillingham City - High School Fire Panel Replacement**FY2001 Request:****\$64,623****Reference No:****AMD 33587****AP/AL:** Appropriation**Project Type:** Health and Safety**Category:** Education**Location:** Dillingham**Contact:** Karen J. Rehfeld**House District:** Bethel, Dillingham (HD 39)**Contact Phone:** (907)465-8650**Estimated Project Dates:** 07/01/2000 - 06/30/2005**Brief Summary and Statement of Need:**

This project is the FY2001 Major Maintenance Grant Fund Priority #61 and is scheduled to begin in FY2002.

Funding:	<u>FY2001</u>	<u>FY2002</u>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>Total</u>
AHFC Bonds	\$64,623						\$64,623
Total:	\$64,623	\$0	\$0	\$0	\$0	\$0	\$64,623

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	
Totals:	0	0

Additional Information / Prior Funding History:**Project Description/Justification:**

This project will upgrade the school's fire panel to meet code. Five pulls and four bells do not work, and the gym, shop, and weight room have no fire protection. The panel has to be replaced because critical components of the panel are no longer being manufactured. Proposed cost: \$92,318.