

Chugach - Tatitlek Fire Alarm Replacement**FY2001 Request: \$35,471**
Reference No: AMD 33625**AP/AL:** Appropriation**Project Type:** Health and Safety**Category:** Education**Location:** Tatitlek**Contact:** Karen J. Rehfeld**House District:** Delta, Prince William Sound (HD**Contact Phone:** (907)465-8650

35)

Estimated Project Dates: 07/01/2000 - 06/30/2005**Brief Summary and Statement of Need:**

This project is the FY2001 Major Maintenance Grant Fund Priority #69 and is scheduled to begin in FY2003.

Funding:	<u>FY2001</u>	<u>FY2002</u>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>Total</u>
AHFC Bonds	\$35,471						\$35,471
Total:	\$35,471	\$0	\$0	\$0	\$0	\$0	\$35,471

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	0
Totals:	0	0

Additional Information / Prior Funding History:**Project Description/Justification:**

This project will replace the existing fire alarm system and associated components and install a security system in the 10,200 square foot, 15-year-old school. Lamps are continually failing and false alarms are a common occurrence. It is feared that students are becoming so used to "false alarms" that they would not react properly were an actual emergency to occur. Additionally, parts are even more difficult to obtain than those for the Whittier system are. It is suspected that the system was not of new design and technology when it was installed 15 years ago. A security system is needed to protect the school from break-ins that have occurred in recent years and to allow surveillance of its aboveground fuel tanks. Proposed cost: \$36,195.