

**Cordova Wastewater Treatment Plant Upgrade Project
Phase 1**

**FY2002 Request: \$1,940,400
Reference No: 34274**

AP/AL: Allocation
Category: Health/Human Services
Location: Cordova
House District: Delta, Prince William Sound (HD 35)
Project Type: Construction
Recipient: City of Cordova
Contact: Dan Easton
Contact Phone: (907)465-5135

Estimated Project Dates: 07/01/2001 - 06/30/2006

Appropriation: Municipal Water, Sewer and Solid Waste Matching Grant Projects

Brief Summary and Statement of Need:

Make corrosion repairs to the existing treatment plant, replace flow meter and recorder, install return activated sludge pumps, upgrade clarifier, and reconstruct an underground vault for the main lift station.

Funding:	FY2002	FY2003	FY2004	FY2005	FY2006	FY2007	Total
AHFC Div	\$485,100						\$485,100
Fed Rcpts	\$1,455,300						\$1,455,300
Total:	\$1,940,400	\$0	\$0	\$0	\$0	\$0	\$1,940,400

<input type="checkbox"/> State Match Required	<input type="checkbox"/> One-Time Project	<input checked="" type="checkbox"/> Phased Project	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	0
Totals:	0	0

Additional Information / Prior Funding History: