

Bethel Heat Recovery Assessment & Conceptual Design

FY2016 Request:

\$645,613

Reference No:

60787

AP/AL: Allocation

Project Type: Energy

Category: Development

Location: Bethel

House District: Lower Kuskokwim (HD 38)

Impact House District: Lower Kuskokwim (HD 38)

Contact: Sara Fisher-Goad

Estimated Project Dates: 07/01/2015 - 06/30/2020

Contact Phone: (907)771-3000

Appropriation: Alaska Energy Authority - Round VIII Renewable Energy Project Grants (AS 42.45.045)

Brief Summary and Statement of Need:

The Alaska Village Electric Cooperative proposes to complete a detailed assessment of the existing 40 year old heat recovery system and prepare a conceptual design report of essential upgrades to the existing system and potential new recovered heat connections. The project would also consider additional heat capture using exhaust gas heat exchangers. Assessment of the existing system would include installation of BTU meters and inline ultrasonic inspection of the 10" pipeline mains. Heat is recovered from the powerhouse's six 2.2 MW EMD 16-645 E4D generators. The application is based on a reconnaissance study completed by Coffman Engineers in 2014.

Funding:	<u>FY2016</u>	<u>FY2017</u>	<u>FY2018</u>	<u>FY2019</u>	<u>FY2020</u>	<u>FY2021</u>	<u>Total</u>
Renew Ener	\$645,613						\$645,613
Total:	\$645,613	\$0	\$0	\$0	\$0	\$0	\$645,613

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	0
Totals:	0	0

Prior Funding History / Additional Information:

Recommendations in the report include ultrasonic inspection, consideration of a list of potential future users of recovered heat, and evaluation of the installation of exhaust gas heat exchangers for system evaluation.