

AP/AL: Appropriation **Project Type:** Deferred Maintenance
Category: Public Protection
Location: Statewide **House District:** Statewide (HD 1-40)
Impact House District: Statewide (HD 1-40) **Contact:** April Wilkerson
Estimated Project Dates: 06/30/2017 - 06/30/2021 **Contact Phone:** (907)465-3460

Brief Summary and Statement of Need:

The Department of Corrections has traditionally used underground storage tanks (UST) for heating fuel and generator fuel storage. The use of one tank for both fuel sources was the most economical way to operate a facility. The Department of Environment Conservation has changed fuel storage requirements and now prohibits combined emergency generator and heating fuel storage without monitoring modifications.

Funding:	<u>FY2018</u>	<u>FY2019</u>	<u>FY2020</u>	<u>FY2021</u>	<u>FY2022</u>	<u>FY2023</u>	<u>Total</u>
1213 AHCC Rcpts							\$0
Total:	\$0	\$0	\$0	\$0	\$0	\$0	\$0

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	0
Totals:	0	0

Prior Funding History / Additional Information:

The unexpended and unobligated balance, not to exceed \$1,850,000, of the appropriation made in sec. 1, ch. 18, SLA 2014, page 50, lines 25 – 27 (Department of Education and Early Development, State Library, Archives and Museum Facility Construction Funding - \$37,500,000) is reappropriated to the Department of Corrections for underground storage tank upgrades.

Project Description/Justification:

Most Department of Corrections (DOC) facilities with UST require separation of fuel sources or additional monitoring devices to meet the new compliance requirements. In order to stay compliant with UST 2018 changes to the DEC regulations, any UST fuel oil systems that are tied into generators must meet the new monitoring requirements.

There are issues at five different facilities: Combined Hiland Mountain Correctional, Palmer Correctional, Yukon Kuskokwim Corrections, Spring Creek Correctional, and Anchorage West Correctional. The consequences of not making the modifications are significant. The DEC would tag the fuel tanks out of service and it would be illegal to continue to fill the tanks.